

DEFENSE ENERGY SUPPORT CENTER
UTILITY PRIVATIZATION
CONTRACTOR'S QUESTIONS
& **ANSWERS #5 (CORRECTED)**

YUMA PROVING GROUND, AZ
(UPDATED: 10 JANUARY 2005)

RFP #: **SP0600-04-R-0113**

CONTRACTING OFFICER: **Terri Workman (703.767.8130)**

CONTRACT SPECIALIST: **Nancy Barnett (703.767.9402)**

1. In order to properly evaluate the pricing as well as the condition on all of the substations, we would appreciate a digital photo of each electrical substation referenced in RFP SPO600-04-R-0113.

ANSWER:	Per our customer, we are unable to provide these photos due to security issues. If you would like to schedule a site visit, please let this office know approximate date(s) and number of visitors. We will then forward this information on to our customer at Yuma Proving Ground for scheduling.
----------------	---

2. I would like a list of the electrical distribution system restoration priorities, in the event of a major outage. This list should contain facilities at Yuma Proving Grounds with the priorities listed in order of most critical to lowest priority.

ANSWER:	The list follows: KOFA Primary Sub/Army Tap Sub B Sub A Subs C, H, et al KOFA Subs Sub F Sub D Sub I
----------------	---